





Installation material:

-FLIXS ventilation ducts	-Drill
-Reciprocating saw / grinder (to cut the duct to the desired length)	-Stainless steel 3/4 self-drilling screws
-Pliers/ cutters/ shears (to cut the pins)	-FLIXSTAPE (to cover screws where installed)
-Steel pins (to attach the FLIXS to the rebar)	-Gloves, goggles, safety boots

Installation instructions:

1 The use of a crane to transport the FLIXS air ducts is recommended.

Use only approved lifting equipment and be sure to follow the recommendations of lifting specialists.

The recommended method is to insert the lifting belt or chain into the center of the air duct rolls as shown in Figure 1.



Figure 1



Forest Energy and Air Solutions Inc. 9265 Le Royer, Montreal (Quebec) Canada H1P 3H7 www.feas.ca

Installation Instructions :

2 - Secure the FLIXS air ducts to the terminal using self-drilling screws, with a minimum of three screws per duct.

Ensure the screws mechanically secure the air ducts for stability (Figure 2).



Figure 2

 Unroll the FLIXS air ducts to the desired length between the air inlet and the discharge box. Make sure the direction of the air ducts is the same as the direction of the air flow. Arrows showing the direction of the air flow are present at both ends of the ducts. Avoid making sharp turns with the air ducts to take full advantage of reduced static pressure loss (Figure 3).



Figure 3



Forest Energy and Air Solutions Inc. 9265 Le Royer, Montreal (Quebec) Canada H1P 3H7 www.feas.ca

Installation Instructions :

4 - Attach the FLIXS air ducts to the lowest rebar with steel wire. Keep a regular interval of approximately 16 inches (30 cm) between each attachment point (Figure 4).



Figure 4

Connect the FLIXS air ducts to the 90-degree elbow, the discharge box, or the next segment of the duct system, depending on your project design. Add a layer of vinyl tape, such as FEAS FLIXSTAPE, on both ends to ensure a secure and airtight seal (Figure 5).





Figure 5

Forest Energy and Air Solutions Inc. 9265 Le Royer, Montreal (Quebec) Canada H1P 3H7 www.feas.ca

Installation Instructions :

6 - When placing bundles of reinforcing bars on installed networks of FLIXS air ducts, use two wooden supports to protect the air ducts. Ensure these supports are doubled up to distribute the weight evenly and prevent damage (Figure 6).




Figure 7



Forest Energy and Air Solutions Inc. 9265 Le Royer, Montreal (Quebec) Canada H1P 3H7 www.feas.ca